

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

This certificate is issued to:

PRODUCER	Scotchmist Limited PO Box 91 Wallington Surry, SM6 0WG United Kingdom (UK)
DESCRIPTION	Turbo-fog, water mist fire suppression nozzles
TYPE	ST 250 ST 350 ST 420 ST 650
APPLICATION	Suppression of fires in non-marine applications.
SPECIFIED STANDARDS	Generally in accordance with the following standards (refer to Tables 1 to 4 below for details): NFPA 750:2003 ASTM E799:2003 ISO 14520:2000 LPS 1230

Certificate No.	05/00102
Issue Date	3 November 2005
Expiry Date	2 November 2010
Sheet	1 of 4



P. F. Moysey
London Plan Approval
Lloyd's Register EMEA

Lloyd's Register EMEA
71 Fenchurch Street, London EC3M 4BS

Lloyd's Register, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register Group'. The Lloyd's Register Group assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register Group entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.